



Product Service

# Attestation of Conformity

No. N8A 072701 0006 Rev. 00

**Holder of Certificate:** **HIMIN CLEAN ENERGY HOLDINGS CO., LTD.**

Sun-moon Mansion, Solar Valley Road  
253090 Dezhou City, Shandong Province  
PEOPLE'S REPUBLIC OF CHINA

**Product:** **Crystalline Silicon Terrestrial Photovoltaic (PV) Modules**  
**Mono-Crystalline Silicon Photovoltaic Module**

This Attestation of Conformity is issued on a voluntary basis according to the Low Voltage Directive 2014/35/EU relating to electrical equipment designed for use within certain voltage limits. It confirms that the listed equipment complies with the principal protection requirements of the directive and is based on the technical specifications applicable at the time of issuance. It refers only to the particular sample submitted for testing and certification. For details see: [www.tuvsud.com/ps-cert](http://www.tuvsud.com/ps-cert)

**Test report no.:** 882162006601

**Date,** 2020-12-02

( Xinlian LUO )

Page 1 of 2

After preparation of the necessary technical documentation as well as the EU declaration of conformity the required CE marking can be affixed on the product. The declaration of conformity is issued under the sole responsibility of the manufacturer. Other relevant EU-directives have to be observed.



Product Service

# Attestation of Conformity

No. N8A 072701 0006 Rev. 00

**Model(s):**

**158.75mmx158.75mm cells module types:**  
HG-xxxS/Ec (xxx=340-390, in step of 5W)  
HG-xxxS/Dc (xxx=285-330, in step of 5W)  
HG-xxxS/Cc (xxx=255-290, in step of 5W)  
HG-xxxS/Bc (xxx=230-260, in step of 5W)  
HG-xxxS/Ac (xxx=170-195, in step of 5W)

**156.75mmx156.75mm cells module types:**  
HG-xxxS/Ea (xxx=340-390, in step of 5W)  
HG-xxxS/Da (xxx=285-330, in step of 5W)  
HG-xxxS/Ca (xxx=255-290, in step of 5W)  
HG-xxxS/Ba (xxx=230-260, in step of 5W)  
HG-xxxS/Aa (xxx=170-195, in step of 5W)

**xxx is standing for rated output power at STC**

## Parameters:

Construction: Framed, with Junction box, Cable and Connectors  
Test Laboratory: Yangzhou Opto-electrical product testing institute  
(10 Kaifa West Rd., Yangzhou, Jiangsu, P. R. China 225009)  
Safety Class: Class II  
Maximum System Voltage: 1000V DC  
Fire Safety Class: Class C according to UL790

## Tested according to:

EN IEC 61730-1:2018  
EN IEC 61730-1:2018/AC:2018-06  
EN IEC 61730-2:2018  
EN IEC 61730-2:2018/AC:2018-06

Page 2 of 2

After preparation of the necessary technical documentation as well as the EU declaration of conformity the required CE marking can be affixed on the product. The declaration of conformity is issued under the sole responsibility of the manufacturer. Other relevant EU-directives have to be observed.